



SCR Catalyst Testing Data Validation Report

Prepared By
Innovative Combustion Technologies, Inc.
10 Commerce Drive, Pelham, AL 35124

August 15, 2022



10 COMMERCE DRIVE
PELHAM, ALABAMA 35214
PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com

Scope

The purpose of this report is to outline the findings from ICT's quarterly instrumentation validation testing. To ensure that only quality data is provided to our partners, ICT conducts a series of testing including:

- Spiked gas testing
- Comparison of O₂ measurements with an external gas analyzer
- EPA Method 4 for water content confirmation
- EPA CTM-027 for NH₃ concentration verification
- Velocity traverses of duct work
- Repeatability testing for deNO_x, SO₂-SO₃ oxidation, and differential pressure
- Repeatability with XRF chemical analysis
- FTIR agreement for non-reactive species (CO₂)

Spiked Gas Testing

ICT's microbench system was setup so that a gas flow mixer using mass flow controllers (MFC) and gas cylinders with certified concentrations of NO, SO₂, and NH₃ were used to generate a gas stream. Two FTIRs, one positioned at the inlet of the test chamber, and the other at the outlet, were exposed to the generated gas stream and measurements for NO, SO₂, and NH₃ were recorded. Figures 1, 2, and 3 show the comparison of the measured gas species from each FTIR compared to the "Actual" concentration of the gas species when simulated by the MFCs. All axes give the concentration of the gas species in ppmvd.



10 COMMERCE DRIVE
PELHAM, ALABAMA 35214
PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com




Figure 1: The FTIR measured NO versus the calculated flow mixer concentration




Figure 2: The FTIR measured NH₃ versus the calculated flow mixer concentration



10 COMMERCE DRIVE
PELHAM, ALABAMA 35214
PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com




Figure 3: The FTIR measured SO₂ versus the calculated flow mixer concentration



10 COMMERCE DRIVE
 PELHAM, ALABAMA 35214
 PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com

Comparison with Testo 350 Gas Analyzer for O₂ Validation

ICT utilizes a multi-probed Yokogawa O₂-Mation device capable of delivering an in-situ wet O₂ reading and an ex-situ dry O₂ reading to a DCS. With no in leakage between the two points of measurement, once the wet-to-dry conversion is made the two readings are nearly identical, providing confidence in the O₂ concentration during all testing. In addition, the Yokogawa device is calibrated daily before testing begins.

ICT further validates the O₂ results by hooking an external analyzer (in this case, a Testo 350 gas analyzer) to a port located on the test chamber, to compare a third reading of O₂. Table 1 shows the comparison data from the DCS indicated reading to the Testo reading.

Table 1: Comparison of O₂ readings indicated by the DCS and the Testo analyzer

O ₂ Validation					
Time	15:46	15:47	15:48	15:49	15:50
DCS O ₂	4.05	4.01	4.00	4.03	4.00
Testo O ₂	3.99	3.98	4.02	3.98	3.95
Abs. Diff.	0.06	0.03	0.02	0.05	0.05
% Diff.	1.5%	0.8%	0.5%	1.2%	1.3%

Method 4 for H₂O Validation

ICT follows the EPA Method 4 to verify the accuracy of the FTIR readings for moisture content in the flue gas. Table 2 shows the comparison of an inlet FTIR, outlet FTIR, and the Method 4 results

Table 2: Comparison of FTIR measured values to the Method 4 indicated value

H ₂ O Validation		
Start Time	9:39 AM	10:03 AM
End Time	9:49 AM	10:13 AM
Method 4	9.70	9.59
Inlet FTIR	10.17	9.98
% Diff, Method 4	4.88%	4.03%
Outlet FTIR	10.26	10.08
% Diff, Method 4	5.81%	5.07%
% Diff, Inlet and Outlet	0.88%	1.00%



10 COMMERCE DRIVE
 PELHAM, ALABAMA 35214
 PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com

CTM-027 for NH₃ Validation

ICT follows the EPA Conditional Test Method 27 to verify the accuracy of the FTIR readings for NH₃ content in the flue gas. Table 3 shows the comparison of the FTIR to CTM-027.

Table 3: Comparison of FTIR measured values to the CTM-027 indicated value

CTM-027 NH ₃ ppm	FTIR NH ₃ ppm	Percent Difference	Absolute Difference
8.03	8.12	1.19%	0.10
4.68	4.54	2.97%	0.14

Velocity Traverse for Flow Validation

In order to validate the DCS indicated flow through the test chamber, a velocity traverse is conducted using a port location just after the test chamber. Table 4 shows the results of the traverse at a nominal 100 scfm setpoint.

Table 4: DCS indicated flow compared to calculated traverse flow at nominal 100 scfm

100 SCFM Setpoint			
Start Time	2:42 PM	2:44 PM	2:46 PM
End Time	2:44 PM	2:45 PM	2:46 PM
DCS Flow	98.4	99.8	102.1
Tested Flow	97.08	98.39	97.06
Error	1.36%	1.43%	5.19%
Avg Error	2.66%		

Repeatability Test – deNO_x, SO₂ Oxidation, and Differential Pressure

The ability to repeat the results of a test is an important part of any test facility. A sample that was tested previously was selected and retested for deNO_x activity, SO₂-SO₃ oxidation, and differential pressure. The results of this repeatability test are presented in Table 5.

Table 5: Activity, SO₂ oxidation, and differential pressure results during repeatability testing

Repeatability Test				
	Jan-21	Full Layer Est.	Jul-22	Full Layer Est.
Length, mm	700.5	1400	700.5	1400
Activity, k	35.1	35.1	33.4	33.4
SO ₂ -SO ₃	0.515	1.030	0.531	1.061
dP	0.15	0.30	0.15	0.30



10 COMMERCE DRIVE
 PELHAM, ALABAMA 35214
 PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com

A small reduction in activity was observed (<5%) after a year and a half of the catalyst sample sitting in storage, with SO₂-SO₃ oxidation and differential pressure showing little to no difference in the results.

Repeatability Test - XRF

XRF is used to analyze the chemical composition of the catalyst as well as identify any uptake of poisons on or within the catalyst. A sample that was tested previously was selected and retested for XRF analysis. Table 6 contains the results of an XRF repeatability test.

Table 6: XRF repeatability test

Species	Units	Run 1	Run 2
TiO ₂	wt%	64.64%	64.45%
WO ₃	wt%	0.04%	0.03%
MoO ₃	wt%	1.48%	1.51%
V ₂ O ₅	wt%	2.37%	2.39%
SiO ₂	wt%	5.19%	4.83%
Al ₂ O ₃	wt%	2.30%	1.98%
CaO	wt%	1.04%	1.03%
MgO	wt%	BDL	BDL
Fe ₂ O ₃	wt%	3.12%	2.86%
SO ₃	wt%	5.21%	4.90%
K ₂ O	ppm	20.60	BDL
P ₂ O ₅	wt%	1.46%	1.38%
Nb ₂ O ₅	wt%	0.13%	0.13%
BaO	wt%	0.04%	0.03%
Cr ₂ O ₃	wt%	2.02%	1.37%
As ₂ O ₃	ppm	86.59	81.41
PbO	ppm	66.96	65.49



10 COMMERCE DRIVE
PELHAM, ALABAMA 35214
PHONE: 205.453.0236 FACSIMILE: 205.453.0239
www.innovativecombustion.com

FTIR Agreement for CO₂

Due to CO₂ remaining unreactive across SCR catalysts, an agreement between the inlet and outlet FTIR provides two reading for CO₂ in the flue gas. A comparison between the two FTIRs can be found in Table 7.

Table 7: Agreement between the inlet and outlet FTIR for CO₂

CO ₂ Agreement			
FTIR	Run 1	Run 2	Run 3
Inlet	8.05	8.07	8.09
Outlet	8.11	8.12	8.13
% Diff	0.74%	0.62%	0.49%